



Government Of West Bengal
Office Of The Divisional Fire Officer,Howrah
West Bengal Fire & Emergency Services
430, G.T. Road, Howrah(N), Pin :- 711101

Memo no.:FSR/0125186231300563

Date: 07-01-2024

From:

Divisional Fire Officer,Howrah
West Bengal Fire & Emergency Services

To: VIVEKANANDA RAMAKRISHNA MISSION B.ED. COLLEGE

VIVEKANANDA RAMAKRISHNA MISSION B.ED.COLLEGE.VILL AND PO-PIRPUR,PS-ULUBERIA,HOWRAH-711303

Sub: Fire Safety certificate for an existing G+II Storied B-Ed college building in the name & style of "VIVEKANANDA RAMAKRISHNA MISSION B.ED. COLLEGE" under group of educational occupancy at MOUZA- CHANDIPUR, DAG NO- 1062,1063, 1064, J.L. NO.- 09, KHATIAN NO.- 1534, 245/1,155/1, P.S.- ULUBERIA, DIST.- HOWRAH, PIN- 711303

This is in reference to your application no. 0125189231300295 dated 30-12-2023 regarding the Fire Safety certificate for an existing G+II Storied B-Ed college building in the name & style of "VIVEKANANDA RAMAKRISHNA MISSION B.ED. COLLEGE" under group of educational occupancy at MOUZA- CHANDIPUR, DAG NO- 1062,1063, 1064, J.L. NO.- 09, KHATIAN NO.- 1534, 245/1,155/1, P.S.- ULUBERIA, DIST.- HOWRAH, PIN- 711303

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a closed circuit T.V system will have to be installed which observe all floor of the buildings.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers confirming I.S. Specification.
10. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.
14. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
15. The Head of the organization / Society as the case may be, shall submit a declaration to the Director General, West Bengal Fire & Emergency Services on every 1st April, 1st July, 1st October, & 1st January maintaining financial calendar that "The Fire Prevention and Fire Safety Measures in the building or premises have been tested and are in good working condition. That, no material changes has been done in the building that has affected the means of escape and means of access as the case may be. That, all the members of the organization are well conversant with the evacuation drill and mentally & physically fit to combat the Fire Emergencies. That, any deviation in the above and failure in maintenance of the Fire Prevention and fire safety measures shall at the risk and liability of the Head of the organization/ Society.

This certificate is valid for 3 years from the date of issue and renewable after three years to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the life & Fire Safety arrangements and installations of the building failing which this shall be revoked automatically.

Signature valid

Digitally signed by RANJAN
KUMAR GHOSH
Date: 2024.01.27 23:26:19 IST

Divisional Fire Officer, Howrah
West Bengal Fire & Emergency Services

Memo No.: FSR/0125186231300563